

06381/06386/06416 [91224] [Safety Relief Valve] 06381/06386/06416  
 Capacity Tests: Sec. VIII Div. 1 at National Board Testing Lab on February 26, 2015  
 Method of Establishing Relieving Capacity: Flow Capacity, Slope  
 Certified Value: 1.700 SCFM/PSIA  
 Media - Test: Air/Gas; Certified: Gas  
 Set Pressure Definition: Initial Audible Discharge  
 Blowdown Characteristics: Fixed  
 Designed by: HEROSE GMBH Armaturen Und Metalle {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
0.5-0.75 NPS	1 NPS	86.6	10.5 mm	2.1 mm	30-363 psi	Air	VIII Div. 1

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE GMBH Armaturen Und Metalle (HEG) Bad Oldesloe, 23843 Germany	VIII Div. 1	05/27/2027