

06216/06217.1 [Safety Relief Valve] 06216/06217.1400
 400 [91145]
 Capacity Tests: Sec. UV at unknown lab on August 26, 2002
 Method of Establishing Relieving Capacity: Flow Capacity, Slope
 Certified Value:16,500 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Flow Area Configuration: Nozzle/Full Lift
 Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
1.5 NPS		805	32 mm ²	12.5 mm	15-232 psi	Air	UV

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE G.M.B.H. ARMATUREN UND METALLE (HEG) Bad Oldesloe, 23843 Germany	UV	04.18.2030