

06216/06217.2 [Safety Relief Valve] 06216/06217.2000  
 000 [91156]  
 Capacity Tests: Sec. UV at unknown lab on August 26, 2002  
 Method of Establishing Relieving Capacity: Flow Capacity, Slope  
 Certified Value:24,800 SCFM/PSIA  
 Media - Test: Air/Gas; Certified: Air, Gas  
 Set Pressure Definition: Initial Audible Discharge  
 Blowdown Characteristics: Fixed  
 Flow Area Configuration: Nozzle/Full Lift  
 Designed by: HEROSE G.M.B.H. ARMATUREN UND METALLE {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
2 NPS		1258	40 mm	15.1 mm	15-174 psi	Air	UV

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE G.M.B.H. ARMATUREN UND METALLE (HEG) Bad Oldesloe, 23843 Germany	UV	04.18.2030