

The manufacturer is awarded the following type test approval mark in virtue of a component test report:

Category type test approval mark:

[safety valve](#)

Technical inspection and surveillance organisation and test report:

TÜV NORD dated 2011-03-14 and 10th supplement dated 2024-06-21

Manufacturer/Distributor:

[HEROSE GmbH](#)
[Armaturen und Metalle](#)
[Elly-Heuss-Knapp-Straße 12](#)
[23843 Bad Oldesloe](#)
[GERMANY](#)

Type test approval mark:

[TÜV . SV . 20 - 1090 . A₀ . S/G \(D/G\) . α_w . p](#)

Design:

direct acting safety valve, spring loaded, free blow off

Type:

[06216, 06218](#) cap
[06205, 06217, 06219, 06C02](#) lifting device

The award is made pursuant to:

- TÜV-Verband-Merkblatt Sicherheitsventil 100, edition 2022-12-14, in conjunction with TÜV-Verband Technical Leaflet General 002, edition 2022-09-20
- Directive 2014/68/EU from 15 May 2014 (Pressure Equipment Directive)
- AD 2000-Merkblatt A 2, edition 2020-01
- AD 2000-Merkblatt A 4, edition 2015-04
- DIN EN ISO 4126-1:2016-12

Valid until:

[2026-03-31](#)

The award may be revoked. The previous certificate is replaced herewith.

Note: The manufacturer or importer must task the authorised inspector with conducting a yearly random check of components from the production line to establish their conformity with the approved type.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

Industry and plant engineering division

www.tuev-verband.de/en